

2019.3.27

珠海容川环保废气处理设施运行记录表

运行时间	设备名称	设备型号	设备功率 / KW	设计风量/m <sup>2</sup>	运行风量/m <sup>2</sup>	洗涤剂初始PH值	补充水量 /吨	洗涤剂后水PH值	设备运行情况	记录人	备注
8.00	1#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0	运行正常	何生华	
8.30	2#喷淋塔	ø2400*600-pp-3	/	/	6.2	2.0	8.0				
9.00	3#喷淋塔	ø2400*600-pp-3	/	/	6.5	2.0	8.0				
9.30	4#喷淋塔	ø2400*600-pp-3	/	/	6.2	2.0	8.0				
10.00	5#喷淋塔	ø2400*600-pp-3	/	/	6.2	2.0	8.0				
10.30	6#喷淋塔	ø2400*600-pp-3	/	/	6.2	2.0	8.0				
11.00	7#喷淋塔	ø2400*600-pp-3	/	/	6.2	2.0	8.0				
11.30	8#喷淋塔	ø2400*600-pp-3	/	/	6.2	2.0	8.0				
12.00	1#管道泵	5.5KW/380V-12m	5.5	480L/min	/	/	/				
13.00	2#管道泵	5.5KW/380V-12m	5.5	480L/min	/	/	/				
14.15	3#管道泵	5.5KW/380V-12m	5.5	480L/min	/	/	/				
15.30	4#管道泵	5.5KW/380V-12m	5.5	480L/min	/	/	/				
16.20	5#管道泵	5.5KW/380V-12m	5.5	480L/min	/	/	/				
17.05	6#管道泵	5.5KW/380V-12m	5.5	480L/min	/	/	/				
17.25	7#管道泵	5.5KW/380V-12m	5.5	480L/min	/	/	/				
18.00	1#UV	GSETMVO-C-30K	30	/	/	/	/	25停	何生华		
18.05	2#UV	GSETMVO-C-30K	30	/	/	/	/				
18.25	3#UV	GSETMVO-C-30K	30	/	/	/	/				
18.40	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>			25停	何生华		
19.05	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						
20.00	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>			25停	何生华		



离心风机	F4-72-10C/30KW	30	31000-43000m³	35000-4000m³				
离心风机	F4-72-10C/30KW	30	31000-43000m³	35000-4000m³				
离心风机	F4-72-10C/30KW	30	31000-43000m³	35000-4000m³				

2019.3.28

珠海容川环保废气处理设施运行记录表

运行时间	设备名称	设备型号	设备功率 / KW	设计风量/m²	运行风量/m²	洗涤剂初始PH值	补充水量 /吨	洗涤剂后水PH值	设备运行情况	记录人	备注
8.0	1#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0	何正华		
8.20	2#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.1			
8.30	3#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.2			
8.40	4#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
8.50	5#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
9.05	6#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
9.25	7#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
10.40	8#喷淋塔	ø2400*600-pp-3	/	/	/						
11.20	1#管道泵	5.5KW/380V-12m	5.5	480L/min	/				何正华		
11.45	2#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
12.50	3#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
13.30	4#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
13.50	5#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
14.50	6#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
15.30	7#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
17.20	1#UV	GSETMVC-30K	30	/	/						
17.55	2#UV	GSETMVC-30K	30	/	/						
18.20	3#UV	GSETMVC-30K	30	/	/						
19.10	离心风机	F4-72-10C/30KW	30	31000-43000m³	35000-4000m³						
19.25	离心风机	F4-72-10C/30KW	30	31000-43000m³	35000-4000m³						
20.00	离心风机	F4-72-10C/30KW	30	31000-43000m³	35000-4000m³						



离心风机 | F4-72-10C/30KW | 30 | 31000-43000m³ | 35000-4000m³

2019.1.21

### 珠海容川环保废气处理设施运行记录表

运行时间	设备名称	设备型号	设备功率 / KW	设计风量/m²	运行风量/m²	洗涤剂初始PH值	补充水量 /吨	洗涤剂后水 PH值	设备运行情况	记录人	备注	
8.0'	1#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0	何占峰			
8.30	2#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0				
8.00	3#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0				
8.25	4#喷淋塔	ø2400*600-pp-3	/	/	/	6.4	2.0	8.0				
10.35	5#喷淋塔	ø2400*600-pp-3	/	/	/	6.12	2.0	8.0				
10.15	6#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0				
11.20	7#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0				
11.25	8#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0				
12.20	1#管道泵	5.5KW/380v-12m	5.5	480L/min	/							
12.40	2#管道泵	5.5KW/380v-12m	5.5	480L/min	/							
13.25	3#管道泵	5.5KW/380v-12m	5.5	480L/min	/							
13.45	4#管道泵	5.5KW/380v-12m	5.5	480L/min	/							
14.00	5#管道泵	5.5KW/380v-12m	5.5	480L/min	/							
14.28	6#管道泵	5.5KW/380v-12m	5.5	480L/min	/							
15.45	7#管道泵	5.5KW/380v-12m	5.5	480L/min	/							
15.25	1#UV	GSETM VOC-30K	30	/	/							
16.45	2#UV	GSETM VOC-30K	30	/	/							
17.20	3#UV	GSETM VOC-30K	30	/	/							
18.28	离心风机	F4-72-10C/30KW	30	31000-43000m³	35000-4000m³							
19.30	离心风机	F4-72-10C/30KW	30	31000-43000m³	35000-4000m³							
20.00	离心风机	F4-72-10C/30KW	30	31000-43000m³	35000-4000m³							



离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>
------	----------------	----	---------------------------	--------------------------

珠海容川环保废气处理设施运行记录表

运行时间	设备名称	设备型号	设备功率 / KW	设计风量/m <sup>2</sup>	运行风量/m <sup>2</sup>	洗剂水初值	补充水量 /吨	洗剂后水PH值	设备运行情况	记录人	备注
8:00	1#喷淋塔	ø2400*600-pp-3	/	/	/	6.0	2.0	8.0	何小军		
8:25	2#喷淋塔	ø2400*600-pp-3	/	/	/	6.0	2.2	8.0			
9:20	3#喷淋塔	ø2400*600-pp-3	/	/	/	6.0	2.0	8.0			
9:45	4#喷淋塔	ø2400*600-pp-3	/	/	/	6.0	2.0	8.0			
9:55	5#喷淋塔	ø2400*600-pp-3	/	/	/	6.0	2.0	8.0			
10:20	6#喷淋塔	ø2400*600-pp-3	/	/	/	6.0	2.0	8.0			
11:25	7#喷淋塔	ø2400*600-pp-3	/	/	/	6.0	2.1	8.0			
11:58	8#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
12:20	1#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
12:40	2#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
13:27	3#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
13:48	4#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
14:20	5#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
15:27	6#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
16:15	7#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
17:35	1#UV	GSETMVC-30K	30	/	/						
17:40	2#UV	GSETMVC-30K	30	/	/						
18:20	3#UV	GSETMVC-30K	30	/	/						
19:15	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						
19:45	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						
20:00	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						



离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>
		30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>

2019.4.1

珠海容川环保废气处理设施运行记录表

运行时间	设备名称	设备型号	设备功率 / KW	设计风量/m <sup>2</sup>	运行风量/m <sup>2</sup>	洗涤剂初始PH值	补充水量 /吨	洗涤剂后水PH值	设备运行情况	记录人	备注
8:0	1#喷淋塔	ø2400*600-pp-3	/	/	/	6.0	2.0	8.0			
8:30	2#喷淋塔	ø2400*600-pp-3	/	/	/	6.0	2.0	8.0			
9:0	3#喷淋塔	ø2400*600-pp-3	/	/	/	6.0	2.0	8.0			
9:45	4#喷淋塔	ø2400*600-pp-3	/	/	/	6.0	2.0	8.0			
10:20	5#喷淋塔	ø2400*600-pp-3	/	/	/	6.0	2.0	8.0			
10:45	6#喷淋塔	ø2400*600-pp-3	/	/	/	6.0	2.0	8.0			
11:15	7#喷淋塔	ø2400*600-pp-3	/	/	/	6.0	2.0	8.0			
11:35	8#喷淋塔	ø2400*600-pp-3	/	/	/	6.0	2.0	8.0			
12:00	1#管道泵	5.5KW/380v-12m	5.5	480L/min	/						
12:30	2#管道泵	5.5KW/380v-12m	5.5	480L/min	/						
13:20	3#管道泵	5.5KW/380v-12m	5.5	480L/min	/						
13:40	4#管道泵	5.5KW/380v-12m	5.5	480L/min	/						
14:25	5#管道泵	5.5KW/380v-12m	5.5	480L/min	/						
15:10	6#管道泵	5.5KW/380v-12m	5.5	480L/min	/						
15:45	7#管道泵	5.5KW/380v-12m	5.5	480L/min	/						
16:15	1#UV	GSETMVC-30K	30	/	/						
16:15	2#UV	GSETMVC-30K	30	/	/						
17:20	3#UV	GSETMVC-30K	30	/	/						
19:48	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						
18:20	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						
20:0	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						



# 珠海容川环保废气处理设施运行记录表

运行时间	设备名称	设备型号	设备功率 / KW	设计风量/m <sup>2</sup>	运行风量/m <sup>2</sup>	洗涤剂初始PH值	补充水量 /吨	洗涤剂后水PH值	设备运行情况	记录人	备注
2017.4.2	1#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0	设备运行正常	李华	
8:10	2#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
8:30	3#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
9:20	4#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
9:40	5#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
10:15	6#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
10:35	7#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
11:20	8#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
11:50	1#管道泵	5.5KW/380V-12m	5.5	480L/min	/				设备运行正常	李华	
12:28	2#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
13:15	3#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
13:40	4#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
14:20	5#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
14:50	6#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
15:15	7#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
16:28	1#IV	GSETMVC-30K	30	/	/						
16:48	2#IV	GSETMVC-30K	30	/	/						
17:22	3#IV	GSETMVC-30K	30	/	/						
17:48	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						
18:50	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						
20:10	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						



	3#UV	GSETMWC-30K	30	/	/						
	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						
	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						
	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						

2019.4.13

珠海容川环保废气处理设施运行记录表

运行时间	设备名称	设备型号	设备功率 / KW	设计风量/m <sup>2</sup>	运行风量/m <sup>2</sup>	洗剂水初始PH值	补充水量 /吨	洗剂后水PH值	设备运行情况	记录人	备注
8:00	1#喷淋塔	φ2400*600-pp-3	/	/	/	6.0	2.8	8.0			
8:10	2#喷淋塔	φ2400*600-pp-3	/	/	/	6.0	2.0	8.0			
8:20	3#喷淋塔	φ2400*600-pp-3	/	/	/	6.0	2.0	8.0			
8:45	4#喷淋塔	φ2400*600-pp-3	/	/	/	6.0	2.0	8.0			
9:15	5#喷淋塔	φ2400*600-pp-3	/	/	/	6.0	2.0	8.0			
9:38	6#喷淋塔	φ2400*600-pp-3	/	/	/	6.0	2.0	8.0			
11:25	7#喷淋塔	φ2400*600-pp-3	/	/	/	6.0	2.0	8.0			
11:48	8#喷淋塔	φ2400*600-pp-3	/	/	/						
12:22	1#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
13:26	2#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
14:25	3#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
15:10	4#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
16:20	5#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
16:45	6#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
17:22	7#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
18:20	1#UV	GSETMWC-30K	30	/	/						
18:45	2#UV	GSETMWC-30K	30	/	/						
19:20	3#UV	GSETMWC-30K	30	/	/						
19:45	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						
19:50	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						
20:00	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						



### 珠海容川环保废气处理设施运行记录表

2019. 4. 4

运行时间	设备名称	设备型号	设备功率 / KW	设计风量/m <sup>2</sup>	运行风量/m <sup>2</sup>	洗涤剂初始PH值	补充水量 /吨	洗涤剂后水PH值	设备运行情况	记录人	备注
	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						
	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						
8:00	1#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0	何志军		
8:30	2#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.2			
9:00	3#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
9:45	4#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
10:15	5#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
10:38	6#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
11:20	7#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
11:40	8#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
12:21	1#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
12:45	2#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
13:27	3#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
13:45	4#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
14:00	5#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
15:40	6#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
15:55	7#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
16:20	1#UV	GSETMVC-30K	30	/	/						
16:45	2#UV	GSETMVC-30K	30	/	/						
17:40	3#UV	GSETMVC-30K	30	/	/						
18:20	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						
19:40	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						
20:00	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						





离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>					
离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>					
离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>					

珠海容川环保废气处理设施运行记录表

运行时间	设备名称	设备型号	设备功率 / KW	设计风量/m <sup>2</sup>	运行风量/m <sup>2</sup>	洗涤剂初 始PH值	补充水量 /吨	洗涤剂后水 PH值	设备运行 情况	记录人	备注
8:00	1#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
8:30	2#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
9:00	3#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
9:30	4#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
10:00	5#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
10:30	6#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
11:00	7#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
11:30	8#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
12:00	1#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
12:30	2#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
13:00	3#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
13:30	4#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
14:00	5#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
14:30	6#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
15:00	7#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
16:00	1#UV	GSETMVC-30K	30	/	/						
17:00	2#UV	GSETMVC-30K	30	/	/						
18:00	3#UV	GSETMVC-30K	30	/	/						
19:00	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						
19:45	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						
20:00	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						



3#UV	GSETMVOC-30K	30	/	/	/						
离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>							
离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>							
离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>							

2019. 4. 6

### 珠海容川环保废气处理设施运行记录表

运行时间	设备名称	设备型号	设备功率 / KW	设计风量/m <sup>2</sup>	运行风量/m <sup>2</sup>	洗涤剂初始PH值	补充水量 /吨	洗涤剂后水PH值	设备运行情况	记录人	备注
8.00	1#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0	何占军		
8.30	2#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
9.20	3#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
9.45	4#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
10.17	5#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
10.30	6#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
11.20	7#喷淋塔	ø2400*600-pp-3	/	/	/	6.2	2.0	8.0			
11.57	8#喷淋塔	ø2400*600-pp-3	/	/	/						
12.10	1#管道泵	5.5KW/380v-12m	5.5	480L/min	/						
12.28	2#管道泵	5.5KW/380v-12m	5.5	480L/min	/						
13.20	3#管道泵	5.5KW/380v-12m	5.5	480L/min	/						
13.50	4#管道泵	5.5KW/380v-12m	5.5	480L/min	/						
14.15	5#管道泵	5.5KW/380v-12m	5.5	480L/min	/						
14.47	6#管道泵	5.5KW/380v-12m	5.5	480L/min	/						
15.00	7#管道泵	5.5KW/380v-12m	5.5	480L/min	/						
15.50	1#UV	GSETMVOC-30K	30	/	/				何占军		
16.10	2#UV	GSETMVOC-30K	30	/	/						
17.20	3#UV	GSETMVOC-30K	30	/	/						
18.55	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						
19.20	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						
20.00	离心风机	F4-72-10C/30KW	30	31000-43000m <sup>3</sup>	35000-4000m <sup>3</sup>						



3#UV	GSE1WVUC-30K	30	/	/	/				
离心风机	F4-72-10C/30KW	30	31000-43000m³	35000-4000m³					
离心风机	F4-72-10C/30KW	30	31000-43000m³	35000-4000m³					

2017. 4  
珠海容川环保废气处理设施运行记录表

运行时间	设备名称	设备型号	设备功率 / KW	设计风量/m²	运行风量/m²	洗涤剂初值	补充水量 /吨	洗涤剂后水 pH值	设备运行情况	记录人	备注
8.0	1#喷淋塔	ø2400*600-PP-3	/	/	/	6.2	2.0	8.0			
	2#喷淋塔	ø2400*600-PP-3	/	/	/	6.2	2.0	8.0			
8.30	3#喷淋塔	ø2400*600-PP-3	/	/	/	6.2	2.0	8.0			
9.10	4#喷淋塔	ø2400*600-PP-3	/	/	/	6.2	2.0	8.0			
9.45	5#喷淋塔	ø2400*600-PP-3	/	/	/	6.2	2.0	8.0			
10.11	6#喷淋塔	ø2400*600-PP-3	/	/	/	6.2	2.0	8.1			
11.35	7#喷淋塔	ø2400*600-PP-3	/	/	/	6.2	2.0	8.0			
12.10	8#喷淋塔	ø2400*600-PP-3	/	/	/	6.2	2.0	8.0			
12.45	1#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
13.10	2#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
13.28	3#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
13.45	4#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
14.10	5#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
14.40	6#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
14.50	7#管道泵	5.5KW/380V-12m	5.5	480L/min	/						
16.10	1#UV	GSETMWC-30K	30	/	/						
16.40	2#UV	GSETMWC-30K	30	/	/						
17.20	3#UV	GSETMWC-30K	30	/	/						
18.15	离心风机	F4-72-10C/30KW	30	31000-43000m³	35000-4000m³						
19.15	离心风机	F4-72-10C/30KW	30	31000-43000m³	35000-4000m³						
19.45	离心风机	F4-72-10C/30KW	30	31000-43000m³	35000-4000m³						
20.00	离心风机	F4-72-10C/30KW	30	31000-43000m³	35000-4000m³						

